



Certificate of Compliance

Certificate: 2337472

Master Contract: 237041

Project: 2337472

Date Issued: February 1, 2011

Issued to: GfG Instrumentation, Inc.

1194 Oak Valley Dr, Ste 20
Ann Arbor, MI 48108
USA
Attention: Tony Poley

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Ying Wang

Issued by: Ying Wang, P.Eng

PRODUCTS

CLASS 4812 05 - SIGNAL APPLIANCES - Systems

CLASS 4812 85 - SIGNAL APPLIANCES - Systems - Certified to US Standards

CI-21 NH3 Transmitter rated at input: 10-30Vdc, 0.19-0.07amp, output: 0.2 to 1mA (4k Ω) or 4 to 20mA (200 Ω), -40C to 55C degree ambient.

Note:

1. The designated model above is evaluated for electrical safety only, and not Certified as a functional safety device. The output signal of this device is used only for indicating purposes.
2. The designated model above is used for non hazardous locations and not evaluated for its IP rating.
3. The designated model shall be supplied by a certified class 2 power supply.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 205-M1983 - Signal Equipment

UL Std No. 916 - Third Edition - Energy Management Equipment



CSA INTERNATIONAL

Certificate: 2337472

Master Contract: 237041

Project: 2337472

Date Issued: February 1, 2011
